



## RFB19-015-23 SECOND FLOOR JAIL RENOVATION

### VENDOR WALK THROUGH QUESTIONS/ANSWERS

---

**Question 1:** What hardware is the County providing for the new security door? Please provide the make/model # & electrical requirements that apply.

**Response:** Southern Folger 1070A-2: Keyed both sides (Combination Spring and Deadlock)

**Question 2:** If door hardware is electrified and not mechanical, where do we run the wire to the existing control location?

**Response:** Hardware is not electrified

**Question 3:** Is there a door position switch required on the new unit? If so, where do you run the wire to the existing control location?

**Response:** N/A

**Question 4:** Is there an owner supplied door closer provided for the new unit? If so, please provide the make/model #.

**Response:** No